

Subject: Statement of Flame Retardancy – Blackback Soft F950/FR02

Waddinxveen, 13 November 2017

Dear Customer,

With this document Texo Trade Services BV declares that the result of the inspection made according to DIN 4102-1 (May 1998) has shown that F950/FR02 meets the classification of polyester with a flame retardant treatment (B1).

The holder of the certificate, who has issued a conformity declaration according to DIN 4102 (May 1998), is under an obligation to use the B 1 mark only in conjunction with the sample initially tested. The conformity is verified by audits.

Conclusion of the test: The tested sample meets the low flammability requirements of Class B1 of building materials under DIN 4102-1 (May 1998)

This authorization is filed under number AJHL1603002392FB.

Kind regards,

Floris-Jan van den Heuvel  
Director  
Texo Trade Services BV

